

# Viking CertainTeed Strandsarking

Version: 1.1

## StrandSarking

Date Started	
Approved Applicator Company	
Viking Licenced Installer	
Project Name & Address	
Main Contractor	
Shingle Profile	
Notes:	

- ☐ StrandSarking Sarking, 3.600 x .800mt x 16.3mm, square edge H3.1 treated substrate for Shingles. Mass 11kg/m<sup>2</sup> BRANZ Appraisal No. 891.
- ☐ Ensure that the roof trusses or framing provides a level surface prior to fastening.
- ☐ Minimum roof pitch: 9°
- ☐ Framing supports at maximum 900mm centres (with maximum cladding weight of 50kg/m<sup>2</sup>).
- ☐ StrandSarking laid at right angles to supports, over at least two spans (three framing members).
- ☐ StrandSarking sheets laid with staggered joints in a brick-bond pattern, with a 3mm expansion gap around all edges.
- ☐ 5mm min. clearance must be left between Strandsarking sheets and any other elements protruding through the roof such as vent pipes. Greater clearances than this may be required around flues and chimneys.
- ☐ StrandSarking sheets must be laid continuous over at least two spans (three framing members). When used over a single span, then blocking (nogs) must be used under each unsupported edge.
- ☐ Block or nog sheet edges at the ridge, gutter, and valleys and where a lower roof meets a wall. No timber support is required at sheet joins, between main supports, throughout the body of the roof.
- ☐ Fixing requirements, use 65mm x 2.8mm ring-shank Galv. or Stainless nails. Fixings must be positioned no closer than 10mm from the sheet edges. Fixing Centres for following Wind-zones...
  - 'Very High & Extra-High' 100mm centres throughout body of sheet, 150mm centres at all sheet ends.
  - 'High' 150mm centres throughout body of sheet, 150mm centres at all sheet ends.

## SUBSTRATE CHECKLIST

JULY 2024

- ☐ Ventilation. A continuous gap of 25mm is required between the underside of the StrandSarking sheet and insulation. Construct substrate to allow ventilation to be equally distributed at the eave intake and ridge vent; this will ensure free airflow directly under the substrate. Ensure a minimum 25mm ventilation gap along all ridges.
- ☐ Ensure the StrandSarking does not protrude into the spouting and that it is capped with a metal drip-edge flashing as per Viking Roofs spec's standard Drip-edge / spouting detail.
- ☐ The maximum exposure period for the StrandSarking before being clad with the roofing system is 8 weeks. It is recommended for the roofing system to be installed as soon as the StrandSarking is laid.
- ☐ When fixed in accordance with the technical literature, StrandSarking is suitable for use in all NZS 3604 building wind zones, up to, and including, Extra High. Please ensure you **have ordered the correct membrane, colour and thickness for your project**

### NOTES:

- Correct substrate installation is critical to durability and performance of the membrane.
- Failure to strictly comply with substrate specification may affect product warranty.
- All constructions should comply with the New Zealand Building Code. Contact your local council for further advice.
- Communication between the Applicator and Construction Company will assist to ensure specification is met.
- Information regarding our products, specifications and warranties is available at [www.vikingroofs spec.co.nz](http://www.vikingroofs spec.co.nz)
- If you have a query regarding this substrate specification, please call Viking on 0800 729 799.

#### Auckland office

80 Alexander Crescent,  
Otara PO Box 14-541,  
Panmure, Auckland  
1741, New Zealand

#### Christchurch office

2 Nazareth Avenue,  
Middleton, PO Box  
9117, Tower Junction  
Christchurch 8149,  
New Zealand

#### Wellington office

19 Pretoria St,  
Lower Hutt 5010,  
New Zealand

T: 0800 729 799  
F: 0800 729 788

[info@vikingroofs spec.co.nz](mailto:info@vikingroofs spec.co.nz)  
[www.vikingroofs spec.co.nz](http://www.vikingroofs spec.co.nz)

A division of Viking Group Limited