

NOTE:
Refer Scupper Detail WSE_041

'Z' = variable according to wind zoning, please refer to table 7 E2/AS1


Gutters must be constructed to minimum of E2/AS1 Fig 52. Viking recommends 150mm vertical height also allowing installation of scupper outlets and overflows.

It is advisable to continue the membrane over the top of the parapet and finish over the front face of exterior cladding

The top of the parapet substrate, must be angled 5° to allow water to run off the top of the parapet
*If no metal cap is to be used, then a 10° slope to the top of parapet is required. Refer E2/AS1 6.5(a)

All fixings for the cap flashing, must be through the side of the flashing.

NOTE:
Substrate to comply with current Viking Roofspect Masterspec specification
Substrate Checksheet available from www.vikingroofspect.co.nz

	DRAWING TITLE	NOTES:	WarmSpan System is Branz Appraised - 713	DRAWING INFORMATION ONLY			
	Viking WarmSpan - Enviroclad Roof Junction_Metal Roof to Internal Gutter	<ul style="list-style-type: none"> * Angle fillets are not required at upstands for Enviroclad * All fixings, cladding and structure are indicative only unless notated * All details to be read in conjunction with Viking Specifications 		Scale:	Date:	Drawn:	Viking
				Not to Scale	01/03/2022		
				VIK_WSE_072_RJUNGUTI			