

NOTE: It is Viking Roofspecs view that Internal Gutters can be eliminated in many cases. In doing so you could reduce the overall heights or increase roof falls while reducing risk and details. To find out more refer to Detail Notes_Best Practice Design in Membrane Roofing

.55g Metal Angle with Hemmed edges to create solid edge for Viking PIR

Viking PIR Polyiso Insulation

Substrate

300mm Min. Gutter width. Falls at 1:100

Refer E2/AS1 paragraphs 8.5.6 and 8.5.10 figures. 64b & 64c

40 mm Weld

Viking Enviroclad TPO waterproofing membrane 1.52 mm thick, install as per manufacturers instructions

NOTE:
Substrate to comply with current Viking Roofspec Masterspec specification Substrate Checksheet available from www.vikingroofspec.co.nz

Viking Vapour Barrier, install as per manufacturers instructions

Substrate

Viking 80mmØ clamped drain SDM049 with 304 S/S domed grate, installed as per manufacturers instructions.

DRAWING TITLE

Viking WarmRoof - Enviroclad
Internal Gutter_with outlet

NOTES:

- * Angle fillets are not required at upstands for Enviroclad
- * All fixings, cladding and structure are indicative only unless noted
- * All details to be read in conjunction with Viking Specifications

WarmRoof System is Branz Appraised - 713

DRAWING

INFORMATION ONLY

Scale:	Date:	Drawn:	Viking
Not to Scale	01/03/2022		

Detail Ref: **VIK_WRE_050_GUTTOUTL**

Viking Roofspec
Taking care of detail