

Metal Cap Flashing to allow for movement specific site details by Designer

Specific Seismic Joint by Designer

100 mm  
Min.

40 mm  
weld

Viking Enviroclad TPO  
waterproofing membrane 1.52 mm  
thick, install as per manufacturers  
instructions

Substrate

NOTE:  
Substrate to comply with current  
Viking Roofspec Masterspec  
specification  
Substrate Checksheet available  
from [www.vikingroofspec.co.nz](http://www.vikingroofspec.co.nz)

Seismic Gap determined by designer

DRAWING TITLE

Viking Enviroclad  
Intersection\_Seismic Gap Generic

NOTES:

\* Angle fillets are not required at  
upstands for Enviroclad  
\* All fixings, cladding and structure are  
indicative only unless notated

**CodeMark**

Cert # GM-CMNZ30058

Cert # BV-CMNZ70176

Enviroclad systems are CodeMarked

DRAWING

INFORMATION ONLY

Scale:

Not to Scale

Date:

23/11/2020

Drawn:

Viking

Detail Ref:

**VIK\_ENV\_063\_INTSSEIS**

**Viking**  
Roofspec  
Taking care of detail