

Viking Roofs spec Single-Ply Membranes

Version 1.0

Concrete

Enviroclad, Dec-K-ing, Epiclad, Butylclad and WarmRoof.

Date Started	
Approved Applicator Company	
Viking Licenced Installer	
Project Name & Address	
Main Contractor	
Membrane Type	
Add any notes or comments:	

- Ensure concrete substrate has been allowed to fully cure – at least 28 days from pour.
- If the concrete is less than 28 days old and a concrete surface sealer has been used or a rapid curing compound, you must identify the product and verify correct curing has taken place prior to laying membrane.
- Relative humidity of concrete substrates must be 75% or less before application. (This can be verified with the use of a hygrometer).
- Viking Roofs spec recommends the use of two coats of Viking Surface Sealer to control moisture within the substrate prior to the Viking Single Ply waterproofing membrane installation.
- Surface to be steel trowel finished smooth, without nibs or voids, clean, dry and free of debris or release agents.
- Fill hollows or holes with a cement plaster, or FLC within limitations of product used.
- Use minimum 50mm bond-breaker tapes over expansion joints.
- Minimum 20mm triangular fillets required at the base of upstands for **Butylclad and Epiclad**. - **Not required for Enviroclad or Dec-K-ing**
- All drains and outlets are membrane compatible. Confirm with Viking Roofs spec if required.
- Ensure consented falls are met. Refer Viking Membrane BRANZ Appraisal and project specification.
- Please ensure you have ordered the correct membrane, colour and thickness for your project

July 2023

SUBSTRATE CHECKLIST



NOTES:

- Cover the substrate to keep it dry, ensuring the waterproofing membrane can be installed when needed. Communicate early with your Viking Approved Applicator on the project scheduling to ensure weather exposure is kept to a minimum. Consider the use of the Viking Surface Sealer for shower protection
- Correct substrate installation is critical to durability and performance of the membrane. Failure to strictly comply with substrate specification may affect product warranty
- All constructions should comply with the New Zealand Building Code. Contact your local council for further advice
- Communication between the Applicator and Construction Company will assist to ensure specification is met

Information regarding our products, specifications and warranties is available at www.vikingroofspec.co.nz If you have a query regarding this substrate specification, please call Viking on 0800 729 799

Auckland office

80 Alexander Crescent,
Otara PO Box 14-541,
Panmure, Auckland
1741, New Zealand

Christchurch office

2 Nazareth Avenue,
Middleton, PO Box
9117, Tower Junction
Christchurch 8149,
New Zealand

Wellington office

19 Pretoria St,
Lower Hutt 5010,
New Zealand

T: 0800 729 799

F: 0800 729 788

info@vikingroofspec.co.nz

www.vikingroofspec.co.nz

A division of Viking Group Limited