

Viking Enviroclad

Version: 1.1

Date Started	
Approved Applicator Company	
Viking Licenced Installer	
Project Name & Address	
Main Contractor	
Membrane Type	
Add any notes or comments:	

- ☐ Falls meet project specification, E2/AS1 or CodeMark Certification.
- ☐ Spanability of installed panels must meet the manufactures specification.
- ☐ Insulated panel is dry and clean with no debris, damage or sharp edges.
- ☐ No sharp protrusions in panels, flashings, or fixings.
- ☐ All fixings are secured and spaced in accordance with manufactures specification.
- ☐ Tape all Insulated panel sheet joins, side and ends with Viking specified tape.
- ☐ Taping to be completed on same day as panel install, by panel installers.
- ☐ Exposed sheet ends where membrane is to be installed must be capped with a fixed metal flashing.
- ☐ All Insulated panel sheet junctions / transitions / flashings are in place and secured.
- ☐ All external edges with a minimum radius of 5mm.
- ☐ Drip-edges are firmly fixed / riveted to Insulated panel.
- ☐ If ELD (Electronic Leak Detection) system is specified, ensure conductive ribbon is installed to specification across the roof assembly.
- ☐ All clamped outlets and overflows are membrane compatible. Note that proprietary Enviroclad scuppers and overflows are fully compatible for hot air welding.
- ☐ Please ensure you have ordered the correct membrane, colour and thickness for your project.

October 2026

SUBSTRATE CHECKLIST INSULATED PANEL

NOTES

- Cover the substrate to keep it dry, ensuring the waterproofing membrane can be installed when needed. Communicate early with your Viking Approved Applicator Company on the project scheduling to ensure weather exposure is kept to a minimum.
- Correct substrate installation is critical to durability and performance of the membrane.
- **Caution:** *Dark membrane colours effect the ability of panels to achieve their maximum spans.*
- Lap taping of Enviroclad TPO to stainless steel scuppers, overflows, sumps or any other stainless steel accessory is not a Viking approved detail.
- Failure to strictly comply with substrate specification may affect product warranty.
- All constructions should comply with the New Zealand Building Code. Contact your local council for further advice.
- Communication between the Applicator and Construction Company will assist to ensure specification is met.
- Information regarding our products, specifications and warranties is available at **www.vikingroofs spec.co.nz**
- If you have a query regarding this substrate specification, please call Viking on 0800 729 799

Auckland office

80 Alexander Crescent,
Otara PO Box 14-541,
Panmure, Auckland
1741, New Zealand

Christchurch office

2 Nazareth Avenue,
Middleton, PO Box
9117, Tower Junction
Christchurch 8149,
New Zealand

Wellington office

19 Pretoria St,
Lower Hutt 5010,
New Zealand

T: 0800 729 799

F: 0800 729 788

info@vikingroofs spec.co.nz
www.vikingroofs spec.co.nz

A division of Viking Group Limited