

Viking Membranes

Version: 1.0

SIP Panel

Enviroclad, Torch-On, Epiclad, WarmRoof

Date Started	
Approved Applicator Company	
Viking Licenced Installer	
Project Name & Address	
Main Contractor	
Membrane Type	
Add any notes or comments:	

- Falls meet project specification
- SIP panel is dry and clean with no debris, damage or sharp edges.
- No sharp protrusions in panels, flashings, or fixings
- All fixings are secured (not loose)
- Sealant at SIP panel sheet joins, side and end, is flush or below top surface of SIP panel.
- All SIP panel exposed sheet ends have been capped with a fixed metal flashing.
- All SIP panel sheet junction flashings are in place and secured.
- All external edges with a minimum radius of 5mm
- Drip-edges are firmly fixed / riveted to SIP panel
- IF ELD (Electronic Leak Detection) system is specified ensure conductive aluminium tape at maximum 3m centres across all joins and junctions between adjacent SIP panels
- Apply Self Adhering Roof Tape to cover over all cleaned substrate sheet joins, sheet junction flashings and Fixing Plates (Viking Licenced Installer to apply)
- All outlets and overflows are membrane compatible. Note that TPO membranes cannot be welded to stainless steel scuppers or sumps. Outlets/overflows must have clamped grates
- Please ensure you have ordered the correct membrane, colour and thickness for your project

July 2023

SUBSTRATE CHECKLIST



NOTES

- Cover the substrate to keep it dry, ensuring the waterproofing membrane can be installed when needed. Communicate early with your Viking Approved Applicator Company on the project scheduling to ensure weather exposure is kept to a minimum
- Correct substrate installation is critical to durability and performance of the membrane
- Failure to strictly comply with substrate specification may affect product warranty
- All constructions should comply with the New Zealand Building Code. Contact your local council for further advice
- Communication between the Applicator and Construction Company will assist to ensure specification is met

Information regarding our products, specifications and warranties is available at www.vikingroofspec.co.nz
If you have a query regarding this substrate specification, please call Viking on 0800 729 799

Auckland office

80 Alexander Crescent,
Otara PO Box 14-541,
Panmure, Auckland
1741, New Zealand

Christchurch office

2 Nazareth Avenue,
Middleton, PO Box
9117, Tower Junction
Christchurch 8149,
New Zealand

Wellington office

19 Pretoria St,
Lower Hutt 5010,
New Zealand

T: 0800 729 799

F: 0800 729 788

info@vikingroofspec.co.nz
www.vikingroofspec.co.nz

A division of Viking Group Limited