

Date Started	
Approved Applicator Company	
Viking Licenced Installer	
Project Name & Address	
Main Contractor	
Membrane Type	
<i>Add any notes or comments:</i>	



Framing supports at 400mm centres (in one direction). All plywood edges must also be supported. **Do not use tongue and groove plywood.** Viking Roofspec can accept the maximum support spacing provided in Table 15C of CCH Ecoply Specification Guide

Minimum thickness 17mm, F8, CCA H3.2 treated, structural plywood (not LOSP treated), CD GRADE with C face upwards

Plywood laid with face grain at right angles to supports

Plywood is to be laid with staggered joints in a brick-bond pattern with a 3mm expansion gap between sheets. **25mm bond-break tape is required** over all ply sheet joints prior to membrane to application

Plywood screw-fixed with 10g x 50mm S/S counter-sunk screws at 150mm centres at all sheet edges and 200mm centres through the body of the sheet. All screws to be counter sunk 1-2mm

Angle Fillets at the base of all upstands. min. 20mm

Chamfer all external edges with a minimum radius of 5mm

Plywood is to be kept dry at all times during construction. Blow/torch drying the plywood surface prior to membrane application does not comply. Plywood and framing supports should be **20% moisture content**

For roofs and roof decks over living spaces, all insulated cavities must be ventilated in accordance with E2/AS1 8.5.2. No cavity ventilation is required for a Viking WarmRoof / WarmSpan system that meets or exceeds the minimum R-value requirements of the climate zone

All outlets and overflows are membrane compatible. Outlets/overflows must have clamped grates

Ensure compliant falls. E2/AS1 8.5.1. limitations state **2° for roofs (1:30 or 34mm/mt), 1.5° for decks (1:40 or 25mm/mt) and 1:100 (10mm/mt) for internal gutters**

Please ensure you have ordered the correct membrane, colour and thickness for your project

NOTES:

- Cover the substrate to keep it dry, ensuring the waterproofing membrane can be installed when needed. Communicate early with your Viking Approved Applicator on the project scheduling to ensure weather exposure is kept to a minimum
- Correct substrate installation is critical to durability and performance of the membrane
- Failure to strictly comply with substrate specification may affect product warranty
- All constructions should comply with the New Zealand Building Code. Contact your local council for further advice
- Communication between the Applicator and Construction Company will assist to ensure specification is met
- Information regarding our products, specifications and warranties is available at www.vikingroofspec.co.nz. If you have a query regarding this substrate specification, please call Viking on **0800 729 799**