

Certificate no: CMNZ70176

Version: 0

Original issue date: 15 April 2025

Version date: 15 April 2025

## 1. Certificate Holder Details



**Viking Roofspec Limited**  
80 Alexander Crescent, Otara, Auckland, 1741  
New Zealand  
info@vikingroofspec.co.nz  
Ph: 0800 729 799  
www.vikingroofspec.co.nz

## 2. Product Certification Body

**Bureau Veritas Australia Pty Ltd**  
Level 11/500 Collins Street  
Melbourne VIC 3000 Australia  
product.certification@bureauveritas.com  
Ph: 1800 855 190  
www.bureauveritas.com.au

**Complaints:** The complaints process for this certificate can be found here:  
[www.bureauveritas.com.au/your-feedback](http://www.bureauveritas.com.au/your-feedback)

Sam Guindi – Bureau Veritas Product  
Certification Manager



BUREAU  
VERITAS

# Product Certificate

## Viking Enviroclad “Sure-Weld TPO” Waterproofing Membrane

### 3. Description of Building Method or Product

Name of the product or method in Aotearoa New Zealand, including any brand names used. Description of what it is and the components that make up any system and its physical attributes including the materials and make-up of the product, where applicable. Matters that should be taken into account in the use or application of the building method or product can be found in item 6. Conditions and Limitations of Use. Continuation of description can be found in item 10 – Supporting Information about Description, [Delete if not applicable]. The building method's or building product's catalogue or model identification number or numbers or other unique identifiers that might be used to identify the building product or building method

Viking Enviroclad “Sure-Weld TPO” Waterproofing Membrane is single ply, polyester fabric reinforced, thermoplastic polyolefin (TPO) waterproofing sheet membrane. It is grey or white and supplied in rolls:

#### 1.14 mm thick

- 2.44 m wide x 30.4 m long
- 3.0 m wide x 30.4 m long
- 3.66 m wide x 30.4 m long
- 4.88 m wide x 30.4 m long

#### 1.52 mm thick

- 2.44 m wide x 30.4 m long
- 3.0 m wide x 30.4 m long
- 3.66 m wide x 30.4 m long
- 4.88 m wide x 30.4 m long

#### 2.52 mm thick FleeceBack

- 3.6 m wide x 30.4 m long

### 4. Intended use of Building Method or Product

Intended use of the building method or product as described in the product manual and other instructional materials. A statement of the function or purpose of the building method or product. Continuation of intended use can be found in item 11 – Supporting Information about Intended use. [Delete if not applicable]

Viking Enviroclad “Sure-Weld TPO” Roof & Deck Waterproofing System is intended to be adhesive bonded or mechanically fixed as waterproofing for roofs, decks, parapets and to line gutters. It may also be installed on a cold roof with insulation installed below the substrate or as a warm roof with insulation installed above the substrate.



This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.

Certificate no: CMNZ70176

Version: 0

Original issue date: 15 April 2025

Version date: 15 April 2025

# Product Certificate

## Viking Enviroclad "Sure-Weld TPO" Waterproofing Membrane



### 5. New Zealand Building Code Provisions

The performance clauses of the New Zealand Building Code that are relevant to the intended use and with which the building method or product complies or contributes to (where used as part of a system).

How the building method or product complies or contributes can be found in item 8. Basis for Certification. Any qualifications on the extent of that compliance can be found in item 6. Conditions and limitations of use.

**B2 Durability:** Performance Clauses B2.3.1 (b)

**E2 External moisture:** Performance Clauses E2.3.1 (contributes to), E2.3.2, E2.3.7

**F2 Hazardous building materials:** Performance Clauses F2.3.1

### 6. Conditions and Limitations of Use

The building method or product's use is to be in accordance with the installation instructions and requirements against which the building method or product was assessed.

Conditions or limitations of conformity for the performance requirements the building method or product is compliant with, including any requirements for people with the qualifications and skills to install or use the building method or product, any known or demonstrated situations where the building method or product should not be used. A statement as to whether there are any matters that should be taken into account in the use or application of the building product or building method and, if so, what those matters are.

1. Viking Enviroclad "Sure-Weld TPO" Waterproofing Membrane is certified for use on buildings:

- a) where the sub-structure is:
  - i. timber designed in accordance with NZS3604 as a light roof; or
  - ii. concrete or other specifically designed sub-structure designed in accordance with verification method B1/VM1 using the structural design actions in AS/NZS1170; and
- b) situated:
  - i. in Wind Zones, up to, and including Extra High (as defined in NZS 3604), and within the scope limitations of NZBC Acceptable Solution E2/AS1 para 1.1 with regards to building height; or
  - ii. in wind pressures up to a maximum design differential ultimate limit state (ULS) of:
    - a. 6.5 kPa when fully bonded; or
    - b. 2.7 kPa when fixed using either of the mechanical fastening methods (HP-X Fasteners and Piranha Plates or Rhino Bond System), and
  - iii. in any exposure zone (as defined in NZS3604) except microclimates; and
- c) where the substrate for the membrane is:
  - i. timber or plywood (CCA or MCA H3.2 treated)
  - ii. OSB (except on decks)
  - iii. Concrete (cast in-situ or pre-cast (directly or with PIR Boards between))
  - iv. Metal tray decks with PIR boards between; and
- d) where the roof or deck is pitched or nominally flat (minimum fall 1:80) and gutters have a minimum fall of 1:100.



This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.

Certificate no: CMNZ70176

Version: 0

Original issue date: 15 April 2025

Version date: 15 April 2025

## Product Certificate

### Viking Enviroclad "Sure-Weld TPO" Waterproofing Membrane



BUREAU  
VERITAS

#### 2. Viking Enviroclad "Sure-Weld TPO" Waterproofing Membrane shall:

- a) be designed and installed in accordance with the Viking Enviroclad Applicator Handbook VK Edition V4 2024 and Details, and
- b) be installed by Viking Approved Applicator /Approved installer (see <https://www.vikingroofspec.co.nz/find-an-applicator/> to find an approved installer), and
- c) be protected where the membrane is subject to pedestrian traffic other than for installation and general maintenance, and
- d) be separated or protected from heat sources such as fireplaces, heating appliances and chimneys.

#### 3. This certification does not cover:

- a) the design and construction of the substrate and movement / control joints;
- b) the weather tightness design of junctions between building elements on specifically designed buildings;
- c) applications where ancillary components other than those provided by Viking Roofspec Limited listed in the installation manual are substituted with alternative products;
- d) PIR insulation incorporated into warm roof construction.

### 7. Health and Safety Information

Health, safety, and well-being declarations associated with installation, maintenance, and use of the building method or product, and their specific editions and dates necessary to ensure the performance requirements of clauses F1 to F9 of the Building Code can be met.

The compliance with any manufacturer's installation instructions, maintenance, OH & S Statements, MSDS's and other Health and Safety declarations will provide the necessary Health and Safety Information pertaining to the product.

### 8. Basis for Certification

How the performance requirements in the Building Code were met for each of the provisions. Where used as part of a system, the specific contribution to compliance.

B2 Durability - By comparison with Verification Method B2/VM1

E2 External moisture - By testing and comparison with Acceptable Solution E2/AS1

F2 Hazardous building materials - By comparison with the performance requirements of Building Code clause F2.3.1



This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.

Certificate no: CMNZ70176

Version: 0

Original issue date: 15 April 2025

Version date: 15 April 2025

## Product Certificate

Viking Enviroclad “Sure-Weld TPO” Waterproofing Membrane



BUREAU  
VERITAS

### 9. Supporting Documentation for Certification

Reference to any acceptable solutions, verification methods, New Zealand Standards, or other compliance pathways referenced against each individual performance requirement the building method or product is compliant with, and their specific version and date. Reference to documents describing tests and evaluations and any other documents relied on for certification or used to prove compliance, including their full title, specific version and date.

1. Acceptable Solutions and Verification Methods for New Zealand Building Code Clause B2 Durability Second edition (Amendment 12), 28 November 2019.
2. Verification Methods E2/VM1 and Acceptable Solutions E2/AS1, E2/AS2 and E2/AS3 for New Zealand Building Code Clause E2 External Moisture Third edition (Amendment 10), 5 November 2020.
3. Acceptable Solutions and Verification Methods for New Zealand Building Code Clause B1 Structure First edition (Amendment 21), 2 November 2023.
4. BRANZ Appraisal 656 Viking Enviroclad Roofing and Deck Membrane, 25 August 2022.
5. BRANZ Test Report DC16105-01 Testing to a Modified Version of EOTA TR004 - Determination of the Resistance to Delamination [Wind Uplift], 22 March 2022.
6. BRANZ Test Report DC13113 Report on Tensile Adhesion Testing Viking Roof Build-ups, 7 July 2020.
7. BRANZ Test Report DC13113-001 Report on Tensile Adhesion Testing of Enviroclad Covered Kinfgspan SIPs, 16 July 2020.
8. BBA Agreement Certificate 21/5986 Product Sheet 1, Carlisle Sure-weld Roof Waterproofing Systems, 14 February 2022.
9. Viking Enviroclad Applicator Handbook VK Edition V4 2024.
10. Details (enviroclad-details-full-set.pdf) 23 Nov 2020.

### 10. Supporting Information About Description (Optional)

Any supporting information for section 3.

Components and accessories intended for use with Viking Enviroclad “Sure-Weld TPO” Waterproofing Membrane are detailed in the Viking Enviroclad Applicator Handbook VK Edition V4 2024:

#### Adhesives

- Sureweld bonding adhesive
- Viking cav-grip III
- Flexible fast dual cartridge adhesive

#### Fixings

- HP-X fasteners
- Piranha plates
- Rhino bond plates



This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.

Certificate no: CMNZ70176

Version: 0

Original issue date: 15 April 2025

Version date: 15 April 2025

## Product Certificate

Viking Enviroclad "Sure-Weld TPO" Waterproofing Membrane



BUREAU  
VERITAS

### Sealants

- Enviroclad cut edge sealant (clear)
- Water cut-off mastic
- Enviroclad universal sealant

### Cleaners/primers for surface preparation

- Enviroclad weathered membrane cleaner
- Hp splice wipes

### Corners etc

- Enviroclad outside and inside corners
- Enviroclad non-reinforced membrane
- Enviroclad t-joint covers
- Enviroclad pipe seal
- Enviroclad split pipe boot
- Enviroclad tpo pourable sealer pockets
- Enviroclad white one-part pourable sealer
- Primer weatherbond
- Laptape

### Accessories

- Enviroclad walkway proprietary non-slip TPO walkway mat with edges trimmed in safety yellow.
- Enviroclad scupper outlets
- Enviroclad scupper overflow
- Sumps with TPO weldable flanges
- Leaf and gravel grates
- Clamp ring roof drains and overflows
- Overflow soffit trim
- Overflow hat
- Termination flashing
- Pedestal system – for use over Enviroclad membrane to support a floating trafficable deck
- Enviroclad Rooftrak Anchor System Ejoyt fixing bar



This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.

Certificate no: CMNZ70176

Version: 0

Original issue date: 15 April 2025

Version date: 15 April 2025

## Product Certificate

Viking Enviroclad "Sure-Weld TPO" Waterproofing Membrane



### 11. Supporting Information About Intended Use (Optional)

Any supporting information for section 4.

N/A

### 12. Supporting Information About Conditions and Limitations of Use (Optional)

Any supporting information for section 6.

N/A

All CodeMark certificates that are current must be registered with MBIE. MBIE maintains a register of valid product certificates. [Please find the register here.](#)

If the certificate is not listed on this register or it appears as (SUSPENDED), it is not a valid CodeMark certificate and does not have to be accepted by a building consent authority as establishing compliance with the New Zealand Building Code.



This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.